



Compliance Statement

Screened Category 6_A ISO/IEC, EN & ANSI/TIA Communication Cable

Eurolan Identification P/N 19C-TA-23xx-xxxx

**Category 6_A Individual Foil without Overall Screen
100 Ω, 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable**

**Eurolan AB
Johannesfredsvägen 12,
SE-168 69 Bromma, Sweden**

Compliance Statement No. 1105630

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6_A performance requirements of edition 1.0 of ISO/IEC Generic Cabling Standard 11801:2017, CENELEC Generic Cabling Standard EN 50173-1:2011, ANSI/TIA Generic Cabling Standard 568-C.2:2009, edition 2.1 of IEC Cable Standard 61156-5:2012 and requirements of CENELEC Cable Standard EN 50288-10-1:2012. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment.1 and IEC 60754-2 The cable has EMC Performance Rating 8. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 4th June 2018

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 4th June 2018

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen".

Jens Rytter Petersen
General Manager